

REAGENT RESISTANCE - PANEL CR900 LOT 07-1087,88

No.	Reagent	Rating	No.	Reagent	Rating
1	Amyl Acetate	0	26	Iodine, Tincture	2
2	Ethyl Acetate	0	27	Methyl Ethyl Ketone	1
3	Acetic Acid 98%	1	28	Methylene Chloride	2
4	Acetone	1	29	Mono Chlorobenzene	0
5	Acid Dichromate 5%	2	30	Naphthalene	0
6	Butyl Alcohol	0	31	Nitric Acid 20%	0
7	Ethyl Alcohol	0	32	Nitric Acid 30%	0
8	Methyl Alcohol	0	33	Nitric Acid 70%	2
9	Ammonium Hydroxide 28%	0	34	Phenol 90%	0
10	Benzene	1	35	Phosphoric Acid 85%	0
11	Carbon Tetrachloride	1	36	Silver Nitrate, Saturated	0
12	Chloroform	1	37	Sodium Hydroxide 10%	0
13	Chomic Acid 60%	2	38	Sodium Hydroxide 30%	0
14	Cresol	1	39	Sodium Hydroxide 40%	0
15	Dichloroacetic Acid	1	40	Sodium Hydroxide, Flake	0
16	Dimethyl Formamide	1	41	Sodium Sulfide, Saturated	0
17	1, 4-Dioxane	0	42	Sulfuric Acid 33%	0
18	Ethyl Ether	0	43	Sulfuric Acid 77%	1
19	Formaldehyde 37%	0	44	Sulfuric Acid 96%	3
20	Formic Acid 90%	1	45	Sulfuric Acid 77% + Nitric Acid 70% (50/50)	2
21	Furfural	2	46	Toluene	0
22	Gasoline	0	47	Trichloroethylene	0
23	Hydrochloric Acid 37%	0	48	Xylenes	0
24	Hydrochloric Acid 48%	3	49	Zinc Chloride, Saturated	0
25	Hydrogen Peroxide 3%	0			

Number of Level 3 Ratings

2

Disposition

Pass

Specification per SEFA 8, 1999

4 or less occurrences of Level 3 Ratings